

Specification

ROME T90 Nylon or TWN75 (-10°C)
MTW, THWN or THHN
PVC - Nylon, 600 Volts

1. SCOPE

- 1.1 This specification describes single conductor Rome T90 Nylon or TWN75 (-10°C), a general purpose building wire insulated with polyvinyl chloride (PVC) and covered with a tough protective sheath of nylon intended for lighting and power circuits at 600 Volts or less, in residential, commercial and industrial buildings. The wire may be operated at 90°C maximum continuous temperature in dry or damp locations and 75°C in wet locations. The wire is C(UL) listed as T90 Nylon or TWN 75 for use in accordance with the Canadian Electrical Code. The wire is also listed by UL as Type THWN or THHN for use in accordance with the National Electrical Code.

2. APPLICABLE STANDARDS

- 2.1 The following standards form a part of this specification to the extent specified herein:
 - 2.1.1 CSA Standard C22.2 No. 75 and Electrical Bulletin No. 1451 for Type T90 Nylon or TWN75, FT 1.
 - 2.1.2 Underwriters Laboratories Standard 83 for Thermoplastic Insulated Wires.
 - 2.1.3 Underwriters Laboratories Standard 1063 for Machine-Tool Wires and Cables (Stranded items only).
 - 2.1.4 Underwriters Laboratories Standard 758 for 105°C Appliance Wiring Materials (Stranded items only).

3. CONDUCTORS

- 3.1 Conductors shall be solid, Class B or Class C stranded, annealed uncoated copper per applicable CSA and UL standards.

4. INSULATION

- 4.1 Each conductor shall be insulated with PVC and sheathed with nylon complying with requirements of UL Standard 83 for Types THHN or THWN, UL Standard 1063 for Type MTW and CSA C22.2 No. 75 for T90 Nylon. In addition, Types THWN or THHN shall comply with the optional Gasoline and Oil Resistant II rating of UL Standard 83. The insulation on stranded sizes shall also comply with UL requirements for 105°C Appliance Wiring Material.
- 4.2 The average thickness of PVC insulation, for a given conductor size, shall be as specified in the applicable CSA and UL standards. The minimum thickness at any point, of the PVC insulation, shall be not less than 90% of the specified average thickness. The minimum thickness at any point of the nylon sheath, shall be as specified in the applicable CSA and UL Standards. The PVC insulation shall be applied tightly to the conductor and shall be free-stripping.

5. IDENTIFICATION

- 5.1 The wire shall be identified by surface marking indicating manufacturer's identification, conductor size and metal, voltage rating, UL Symbol, type designations and optional ratings. The wire shall also be identified as C(UL) Type T90 Nylon or TWN75, FT1.

6. TESTS

- 6.1 Wire shall be tested in accordance with the requirements of UL Standard 83 for Types THWN or THHN wire and for the optional Gasoline and Oil Resistant II listings; as Type MTW to UL Standard 1063 (stranded items); as AWM to UL Standard 758 (stranded items); and as C(UL) Type T90 Nylon or TWN75.

7. LABELS

- 7.1 The wire shall bear the Underwriters Laboratories labels for Types THWN or THHN (solid conductors) and Type MTW (stranded conductors) and the C(UL) label for Types T90 Nylon or TWN75, FT1.