

ROME INTERLOCKED ARMOR POWER CABLE, 5000 VOLTS

3 Conductor, Rome-XLPE Insulated, Nonshielded, Aluminum or Steel Armor
Type MV-90 or Type MC, CT Use

<p>APPLICATION: As armored Type MV-90 cable for installation aerially or in rack, tray, trough, cable trays, or direct buried; for power circuits not exceeding 5000 volts in manufacturing and processing plants, substations and generating stations. May be used in NEC Class I and II, Div. 2 and Class III, Div. 1 and 2 hazardous locations.</p> <p>STANDARDS:</p> <ol style="list-style-type: none"> Listed by UL as Type MV-90 cable per Standard 1072. Also suitable for use as Type MC cable per Standard 1569. Overall jacket UL listed as Sunlight Resistant. Cables pass UL and IEEE-383 ribbon burner flame tests and are UL listed For CT Use. Cables pass IEEE-1202/CSA FT4 (70,000 BTU/hr) cable tray flame test. Cables pass ICEA 210,000 BTU/hr. ribbon burner flame test. Cables UL listed for Direct Burial. Cables conform to ICEA S-96-659, NEMA WC71 for Nonshielded Cables Rated 2001-5000 Volts. <p>CONSTRUCTION: Three conductors of stranded copper, conductor shield, Rome-XLPE (crosslinked polyethylene) insulation, surface print phase identification. Three conductors twisted together with one uncoated copper grounding conductor, suitable fillers, binder tape, aluminum or galvanized steel interlocked armor, yellow sunlight-resistant PVC jacket overall.</p>										
Size AWG or kcmil	No. of Strands	Insul. Thick. Mils	Nom. Diam. Over Armor Inches	PVC Jkt. Thick Mils	Nom. Diam. Over PVC Jkt. Inches	COPPER PHASE CONDUCTORS				
						Copper Grounding Conductor AWG	Approx. Net Wt. Lb./1000 Ft.		Ampacity *	Ampacity **
							Alum. Armor	Steel Armor		
5000 VOLTS, NONSHIELDED, 100% and 133% INSULATION LEVELS										
8	7	110	1.02	50	1.12	8	675	810	52	59
6	7	110	1.10	50	1.20	6	780	1000	69	79
4	7	110	1.19	50	1.30	6	960	1230	91	105
2	7	110	1.32	50	1.43	6	1270	1560	125	140
1	19	110	1.41	50	1.51	4	1560	1870	140	160
1/0	19	110	1.49	50	1.60	4	1820	2200	165	185
2/0	19	110	1.59	60	1.71	4	2115	2485	190	215
3/0	19	110	1.77	60	1.90	3	2780	3125	220	250
4/0	19	110	1.85	60	1.98	3	3105	3750	255	285
250	37	120	2.04	60	2.17	3	3700	4200	280	320
350	37	120	2.21	60	2.35	2	4740	5365	350	395
500	37	120	2.49	75	2.65	1	6515	7200	425	485
750	61	130	2.92	75	3.09	1/0	9315	10225	525	615

* **AMPACITY** for cables installed in uncovered cable tray without maintained spacing; 90°C conductor temperature, 40°C ambient.

** **AMPACITY** for cables installed in uncovered cable tray with maintained spacing of one cable diameter; 90°C conductor temperature, 40°C ambient. For other installation conditions refer to the NEC.

Information on this sheet subject to change without notice.

Specification

ROME INTERLOCKED ARMOR POWER CABLE, 5000 VOLTS, 100% AND 133% INSULATION LEVELS

3 Conductor, Rome-XLPE Insulated, Nonshielded,
Aluminum or Steel Armor

Type MV-90 or Type MC, CT Use

1. SCOPE

- 1.1 This specification describes three conductor Rome-XLPE (thermosetting crosslinked polyethylene) insulated, nonshielded, aluminum or galvanized steel interlocked armor Type MV-90 power cable for use in circuits not exceeding 5000 volts phase to phase at conductor temperatures of 90°C for continuous normal operation, 130°C for emergency overload conditions and 250°C for short circuit conditions. Cables are intended for installation indoors or outdoors, aerially, in rack, trough or cable trays, or for direct burial.

2. STANDARDS

- 2.1 The following standards shall form a part of this specification to the extent specified herein:
 - 2.1.1 UL Standard 1072 for Type MV-90 cable.
 - 2.1.2 ICEA Pub. No. S-96-659 and NEMA Pub. No. WC71 for Nonshielded Cables Rated 2001-5000 Volts.

3. CONDUCTORS

- 3.1 Class B stranded annealed uncoated copper per Part 2 of ICEA.

4. CONDUCTOR SHIELD

- 4.1 The conductor shall be covered with a layer of semiconducting tape completely covering the conductor firmly bonded to the cable insulation. The conductor shield shall meet the requirements of Part 3 of ICEA.

5. INSULATION

- 5.1 Directly over the conductor shield shall be applied a homogeneous wall of Rome-XLPE insulation. The average thickness of insulation shall be 110 mils in sizes 8-4/0 AWG, 120 mils in sizes 250-500 kcmil, and 130 mils in size 750 kcmil. Minimum thickness at any point shall be not less than 90% of the specified thickness. Physical and electrical properties of the insulation shall be in accordance with Table 4-5, Type X-1 of ICEA.

6. PHASE IDENTIFICATION

- 6.1 The insulated phase conductors shall be printed with the numerals "1", "2" and "3" on the surface of the insulation.

7. ASSEMBLY

- 7.1 Three phase conductors shall be cabled together with a Class B stranded, uncoated copper grounding conductor and suitable fillers to make round. Length of lay shall not exceed 35 times the phase conductor diameter. The grounding conductor shall comply with the requirements of UL Standard 1072.

8. CABLE TAPE

- 8.1 A suitable cable tape shall be applied over the assembly to hold the core together and provide bedding for the armor.

9. ARMOR

- 9.1 An aluminum or galvanized steel interlocked armor shall be applied over the cable core. Armor shall be in accordance with UL Standard 1072 and Paragraph 5.3.3 of ICEA.

10. COVERING

- 10.1 An extruded covering of PVC shall be applied over the armor. The average thickness and properties of the PVC covering shall be as specified in Paragraph 5.3.9 of ICEA. Minimum thickness at any point shall be not less than 70% of the required average thickness. The covering shall meet the Sunlight Resistant requirements of UL.

11. IDENTIFICATION

- 11.1 An ink print legend shall be applied to the surface of the PVC covering providing cable and manufacturer identification.

12. TESTS

- 12.1 Cable shall be tested in accordance with UL requirements for Type MV-90 cable and ICEA S-96-659. Certified Test Reports may be furnished, if requested prior to production of the cable.